



Kurs	Sikring	Kabel	Beskrivelse
XQ20	Eff.br 250A 3P	3X240mm AL KW20	Varmepumpe på tak
XQ21	Eff.br 63A 3P		Reserve
XQ22	Eff.br 100A 3P		Reserve
XQ23	Eff.br 125A 3P		Reserve
XQ24	Eff.br 250A 3P		Reserve
XQ25	Eff.br 63A 3P		Gruppesikring
XF101	C16A 3P 30mA	2x2,5mm KW101	Tilførsel gruppe D +FD
XF102	C16A 3P 30mA	2x2,5mm KW102	Tilførsel gruppe C
XF103	C16A 3P 30mA		Reserve
XF104	C16A 2P 30mA		Reserve
XF105	C16A 2P 30mA		Reserve

Rev.	Dato	Rev. gjelder	Nr.	Saksb.	Sidem.k	Oppdr.ansv.			
		Fylkeshuset i Bodø							
TITTEL: HOVEDFORDELER +432.001			SAKSNR.	FILNR.	TEGN.	SAKSB.	KONTR. DATO:		
230V IT / 50Hz			A125812	E432-001	RUBE	RuBe	28.05.19		
			FAG	TYPE	AVSNITT	ETG	LØPE.NR	BL.NR.	REV.
			E 432.001				2	—	
							N.BL.	2	